

Certificate

Registration No.: PV 60026301

Page 1

Report No.: 21207938-4

License Holder:
Sunrise Energy Technology Co., Ltd.
Suite 1501, Bank of East Asia
Harbour View Centre
56 Gloucester Road
WANCHAI
HONGKONG

Manufacturing Plant :
000--21139546 001

Product:
PV Module
Types: SR-xxP6
(xx = 75 - 95 with increments of 5)
SR-xxxP6
(xxx = 100 - 150 with increments of 5)
SR-xxxP6
(xxx = 155 - 180 with increments of 5)
SR-xxxP6
(xxx = 185 - 285 with increments of 5)

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 6 August 2013.



Cologne, 31 July 2009

Dipl.-Ing. M. Adrian